

# Water Softener



01422 833121

[www.springhillwaterservices.co.uk](http://www.springhillwaterservices.co.uk)

## Specifying

For the removal of hard water a Base Exchange water softener shall be installed on the incoming mains or prior to the relevant equipment. Size should be as recommended by the manufacturer.

The water softener shall recharge using tablet salt which should be topped up periodically.

The water softener shall connect to a drain so that rinse water can be discharged into a suitably sized tundish or drain channel.

The unit shall connect to the mains operate from a 230 / 240, single phase, 50Hz fused power supply.

The unit shall be a Springhill WS water softener detailed in the adjacent table.

### Springhill Water Services Ltd

22 Wharf Street  
Sowerby Bridge  
West Yorkshire  
HX6 2AE

t/ 01422 833121

f/ 01422 833141

e/ [info@privatewatersupplies.org.uk](mailto:info@privatewatersupplies.org.uk)

w/ [www.privatewatersupplies.org.uk](http://www.privatewatersupplies.org.uk)

Item	Rating
Configuration options	Simplex or Duplex
Control valve	Manual or Electronic
Maximum flow rate	Low pressure mercury
Minimum flow rate	___m <sup>3</sup> /cm <sup>2</sup> @ a flow of ___m <sup>3</sup> /h
Maximum operating pressure	8 BAR
Amount of water used between each regeneration	_____litres
Amount of water used during regeneration	_____litres
Type of salt used	Tablet Water Softener Salt
Salt consumption per regeneration	_____Kg